

<https://doi.org/10.21122/1029-7448-2021-64-4-314-327>

УДК 621.316.37.064.1

Comparative Analysis of Measures and Technical Means for Suppressing the Aperiodic Current Component in Circuit Breaker

V. V. Kuchanskyi¹⁾

¹⁾Institute of Electrodynamics of the National Academy of Sciences of Ukraine (Kyiv, Ukraine)

© Белорусский национальный технический университет, 2021
Belarusian National Technical University, 2021

Abstract. Electromagnetic transients are considered in the implementation of three-phase automatic reclose on the transmission line of extra high voltage 750 kV. The influence of automatic shunting of phases and pre-insertion active resistance for limiting the characteristics of the aperiodic component of the current, which obstructs the transition of full current through zero, is evaluated. The paper analyses measures taking into account the effect of changing the degree of compensation of charging power and the angles of switching on an SF6 circuit breaker. Sub-schemes of disconnected undamaged phases of the extra high voltage transmission line for the investigation of the aperiodic current component have been developed. The values of the pre-insertion active resistances of different connection and automatic shunting of the phases are determined at which there is an effective reduction of the characteristics of the aperiodic component of the current. In the software environment, a model was developed and switching transient processes were simulated in the 750 kV transmission line. Operating modes that are potentially dangerous for SF6 circuit breakers are determined and recommendations are given to avoid them. Currently the technical and economic requirements for power transmission lines designed for the transport of electricity from large power plants and for the communication of powerful energy systems are increasing. Today there is the importance of reducing specific investment in the construction of new and reconstruction of existing lines. The solution of these issues is associated with the maximum use of power lines by increasing their power transfer capability and controlling modes, especially in operating emergency conditions and post-emergency operation of power systems.

Keywords: electromagnetic transients, automatic phase shunting, three-phase automatic reclose, aperiodic component of current, active pre-insertion resistors

For citation: Kuchanskyi V. V. (2021) Comparative Analysis of Measures and Technical Means for Suppressing the Aperiodic Current Component in Circuit Breaker. *Energetika. Proc. CIS Higher Educ. Inst. and Power Eng. Assoc.* 64 (4), 314–327. <https://doi.org/10.21122/1029-7448-2021-64-4-314-327>

Сравнительный анализ мероприятий и технических средств для подавления аperiodической составляющей в токе линейного выключателя

В. В. Кучанский¹⁾

¹⁾Институт электродинамики Национальной академии наук Украины (Киев, Украина)

Реферат. В статье рассматриваются электромагнитные переходные процессы при реализации трехфазного автоматического повторного включения на линии электропередачи

Адрес для переписки

Кучанский Владислав Владимирович
Институт электродинамики
Национальной академии наук Украины
просп. Победы, 56,
03057, г. Киев, Украина
Тел.: +38 050 387-89-42
kuchanskiyvladislav@gmail.com

Address for correspondence

Kuchanskyi Vladislav V.
Institute of Electrodynamics
of the National Academy of Sciences of Ukraine
56, Peremogy Ave.,
03057, Kyiv, Ukraine
Tel.: +38 050 387-89-42
kuchanskiyvladislav@gmail.com

сверхвысокого напряжения 750 кВ. Анализируются предвключенные активные сопротивления, управляемые шунтирующие реакторы, неполнофазные режимы работы шунтирующих реакторов, автоматические шунтирования фазы с учетом изменения степени компенсации зарядной мощности и углов включения элегазовых выключателей. Разработаны схемы замещения отключенных неповрежденных фаз линии сверхвысокого напряжения для исследования аperiodической составляющей тока. Оценены значения активных предвключенных сопротивлений и автоматического шунтирования фаз на снижение характеристик аperiodической составляющей тока. Разработана имитационная модель и смоделированы переходные процессы на линии электропередачи 750 кВ. Выполнены серии моделирований электромагнитных переходных процессов на реальных линиях электропередачи сверхвысокого напряжения. Проанализированы причины аварий линейных элегазовых выключателей при коммутации компенсированных воздушных линий 750 кВ. Изучены электромагнитные процессы в компенсированных линиях электропередачи в зависимости от начальных условий в момент коммутации. Выявлены моменты резкого изменения параметров переходных процессов при коммутации в линиях сверхвысокого напряжения. Оценено влияние суммарных индуктивностей и активных сопротивлений на характеристики аperiodической составляющей. Выведены аналитические зависимости постоянной времени аperiodической компоненты от момента коммутации и значений суммарного активного сопротивления и индуктивности. Рассмотрены мероприятия для ограничения продолжительности существования аperiodической составляющей тока. Указано, что избежать аварийного режима работы можно соответствующей настройкой устройства контроля коммутации элегазовых выключателей. Даны рекомендации по предупреждению возникновения и развития аварийного режима на подстанциях с элегазовыми выключателями.

Ключевые слова: электромагнитные переходные процессы, автоматическое фазовое шунтирование, трехфазное автоматическое повторное включение, аperiodическая составляющая тока, активные предвключенные резисторы

Для цитирования: Кучанский, В. В. Сравнительный анализ мероприятий и технических средств для подавления аperiodической составляющей в токе линейного выключателя / В. В. Кучанский // *Энергетика. Изв. высш. учеб. заведений и энерг. объединений СНГ*. 2021. Т. 64, № 4. С. 314–327. <https://doi.org/10.21122/1029-7448-2021-64-4-314-327>

Introduction

Due to the modernization of the switching equipment, viz. replacement of air circuit breakers with SF6 circuit breakers in the bulk electrical networks, there was a need to analyze the switching transients in 750 kV extra high voltage (EHV) transmission lines. Due to the lacks of experience in operating SF6 circuit breakers at 750 kV EHV substations, accidents have occurred which have significantly reduced the reliability of the bulk electrical networks operation [1–6]. One of the typical examples of switching that causes damage of SF6 switch is the fast on/off cycle [1–3].

Such a typical switching example is the cycle of a three-phase automatic recloses (TPAR) in the event of a non-liquidated metal short circuit in one of the phases. In case of unsuccessful TPAR, the damaged phase is switched on to the non-liquidated short circuit and the damaged phases are switched-off. After switching on the non-damaged phases, there may be an aperiodic current component i_{acc} (ACC) with characteristics values are significantly higher than the maximum permissible operation data of the SF6. Exceeding the value i_{acc} and duration T_{ap} of the ACC leads to a delay in the transition due to zero full

transient current (Fig. 1). A durable damping process i_{acc} with a value exceeding the maximum allowed prevents the full current from passing through zero, resulting in damage to the gas switch chamber. According to the requirements specified in [7], the ACC value may not exceed 58 %.




Fig. 1. Total transient current

It is assumed that when the switch is off, arc extinguishing occurs in each phase at the moment when the current passes through a zero value. Since the dispersion in the action of the poles of a SF6 circuit breaker when switched on does not exceed 0.001 s, the contacts are simultaneously closed. So, in the case of an unsuccessful TPAR, when the arc on the overhead line during the TPAR pause did not go out, it is possible to delay significantly the process of arc extinction [1–3].

A significant aperiodic component in the switching currents occurs not only with whole groups of shunt reactors. As a result of a series of transient calculations, the most unfavorable moments of contact closure after a TPAR pause and the moments of disconnection of an uncorrected failure by the value of the aperiodic component were found.

The objective of this work is to identify the conditions for the appearance of an aperiodic component in the current, to analyze the process of damping it using pre-insertion resistors, and also to analyze alternative solutions to the problem as a whole

The reason for the appearance of the aperiodic component of the current during switching

In the studies [7–10], the simultaneous influence of the above measures on the significance of the ACC characteristics was not considered. The studies analyzed the effect of pre-insertion active resistances on the gas switch on magnetization currents and resonant over-voltages when switching on the EHV power line to the unloaded autotransformer. There are also studies [11, 12] devoted to the estimation of the influence of pre-insertion active resistances and the moment of switching on the value of the ACC characteristics without analyzing the effect of changing the degree of the line charging power compensation.

It should be noted that there are known works on the use of automatic phase shunting (APS) during single phase automatic re-closure (SPAR) to compensate for the recharge arc and elimination of abnormal resonance over-voltages [12–16]. Studies on the evaluation of the effects of ASF when performing the TPAR are also given. There are also no studies to compare the different types of connection of pre-insertion active resistors to the values of the characteristics of the AC current. As it was shown by the previous studies, the application of only reducing the degree of charge power compensation and the use of controlled switching do not always effectively reduce the ACC [1–3, 7, 8].

This paper deals with the switching off / switching on of the low-voltage transmission line to short-circuit one of the phases, which leads to the activation of TPAR. Studies have shown that the changes in the switching angle of the gas switch and the change in the degree of compensation of the charging power of the low voltage transmission line cannot effectively reduce the aperiodic component to the given values [17].

The total current value in the switch $i_C(t)$ is determined by the expression

$$i_C(t) = i_{inv}(t) + i_{ap}(t) + i_{osc}(t), \quad (1)$$

where $i_{inv}(t) = I_{inv} \cos(\omega t + \alpha - \Psi)$ – involuntary component current in circuit breaker, A; I_{inv} – amplitude of involuntary value of current, A; ω – angular velocity, rad/s; α – moment of commutation, electrical degree; Ψ – phase of involuntary value of current, electrical degree; $i_{ap}(t) = I_{ap} \sin(\alpha - \varphi) e^{-t/\tau}$ – aperiodical component in circuit breaker, A; I_{ap} – amplitude of aperiodical component, A; φ – angle of lag, electrical degree; t – time of electromagnetic transient, s; τ – damping constant of the ACC, s; $i_{osc}(t) = I_{tr} e^{-t/\tau_{osc}} \cos(\omega t + \alpha - \Psi_{tr})$ – decaying current transient component in circuit breaker, A; I_{tr} – amplitude of decaying transient component, A; τ_{osc} – damping constant of decaying current transient component, electrical degree; Ψ_{tr} – phase of decaying transient component, electrical degree.

The initial value of the current aperiodic component depends on the moment the circuit breaker closes (for example, if the switch-on occurs when the instantaneous value of the mains voltage is close to zero, then the aperiodic component has the largest value equal to the amplitude of the periodic component of the current). The damping time constant of the aperiodic current is determined by the ratio of the active and inductive resistances in its circuit.

The aperiodic time constant of the aperiodic component depends on the ratio of the inductance and resistance of the circuit

$$\tau = \frac{L_{\Sigma}}{R_{\Sigma}}, \quad (2)$$

where L_{Σ} – equivalent inductance of an equivalent circuit; R_{Σ} – equivalent resistance of the equivalent circuit.

So, the initial value of the ACC current component depends of values (1). In Fig. 2 the aperiodical (AP) current in phase A in cycle of TPAR are shown. The permissible value of ACC component for SF6 circuit breakers 750 kV is 58 % of total current at the transition process. On the figure I_a – current of the A phase.




Fig. 2. Excess of ACC component the maximum permissible value

Measures and technical means of improving the reliability and efficiency of EHV power transmission lines due to switching

The main task of existing measures and means used in EHV power transmission lines is to increase the reliability and operational efficiency of the operating modes of the main electric networks that they form. There are innumerable modes of operation of power lines, especially for operational normal operating modes. Normal modes of electrical networks mean those that allow long-term operation without any restrictions for both consumers and equipment of the networks themselves. But when critical deviations of parameters values of an electric network are reached, it is necessary to speak already about occurrence of an abnormal mode for which the use of traditional controls methods will be inadequate and therefore ineffective. The consequences of uncontrolled abnormal mode can be not only the deterioration of the technical and economic performance electrical network, but also damage to the equipment of responsible consumers, as well as failure of the main equipment of the network itself with the further development of a system crash.

It should be noted that classification of abnormal modes, which occur in the abnormal nonsinusoidal and nonsymmetrical modes of EHV power lines is given in [12–16]. The use of the term of abnormal mode is not accidental, because when working out literary sources [1–10] and studies of experimental results [12–14, 16], it was concluded that this kind of modes is fundamentally different from traditional ones. The difference and the special characteristics of mode is that they are caused by an abnormal regime, primarily due to the effect of the distortion source. In [15, 16], the division of this mode type into two main categories, depending on the resonance at a certain frequency, is shown on the basic harmonic and higher harmonic components.

Also, this developed classification of abnormal modes includes the considered form of the TPAR operation mode. An abnormal mode of operation exists during the implementation of the TPAR cycle and until the breaker is possibly damaged.

In EHV power lines, the following measures and technical measures apply, shown Fig. 3:

a) the use of pre-insertion resistances in SF6 circuit breakers, which can be connected in series or in parallel (Fig. 3a, b);

b) applications of automatic phase shunting when a phase disconnected is shunted by circuit breakers (Fig. 3c);

c) the controlled switching to ensure switching moments at the required time (Fig. 3d);

d) disconnecting of groups of shunt reactors, as well as the use of open-phase modes of groups shunt reactors (Fig. 3e).

At Fig. 3 L_M, L_E – inductance of the shunt reactor which compensate capacitance between phases and capacitance between phase and earth, H; L_L – inductance of the transmission line, H; R_L – active resistance of the transmission line, Ω ; L_{S1}, L_{S2} – equivalent inductance, H; R_{S1}, R_{S2} – active resistance, Ω ; R_{pre} – active pre-insertion resistance of SF6 circuit breaker.




Fig. 3. Equivalent circuits of phase extra high voltage transmission line

The aperiodic time constant of the aperiodic component in case of application pre-insertion connected in series

$$\tau = \frac{AB(R_{pre}^2(2M+I) + 2R_{pre}A + 2R_{pre}(FR_{S1} + GR_{S2}) + C(R_{pre} + R_{S1})(R_{pre} + R_{S2}) + R_{pre}I(R_{S1} + R_{S2}) + CR_{S1} + D(2M+I))}{\times (AK + L_{S1}L_{S2}(L_L L_M + L_L L_E + L_E L_M))} \rightarrow \quad (3)$$

where $A = L_L L_M L_E, H^3$; $B = L_{S1} L_{S2}, H^2$; $C = R_L R_M R_E, \Omega$; R_M – equal active resistance of phase to phase component shunt reactor, Ω ; R_E – equal active resistance of ground component shunt reactor, Ω ; $D = R_{S1} R_{S2}, \Omega$; $E = R_{S1} + R_{S2}, \Omega$; $F = R_L R_M, \Omega$; $G = R_L R_E, \Omega$; $I = R_M R_E, \Omega$; $K = L_{S1} + L_{S2}, H$; $M = F + G$.

The aperiodic time constant of the aperiodic component in case of application pre-insertion resistors connected in parallel

$$\tau = \frac{AB(R_{pre-ins}CE + RD(2F+I) + 2CD)}{R_{pre-ins}CD(A(L_{S1} + L_{S2}) + L_{S1}L_{S2}(2L_L L_M + 2L_L L_E + L_M L_E))}, \quad (4)$$

where $R_{pre-ins}$ – resistance of pre-insertion resistance, Ω .

The above measures have proven themselves well in suppressing and limiting the characteristics of abnormal resonant over-voltages in non-sinusoidal and asymmetric operating modes [13–16, 18–20]. It should be noted that today there is no work to assess the impact of measures and means on the aperiodic component of the total transient current (1) and especially aperiodic time constant (2).

Switch with pre-insertion active resistor can be used to extinguish large multiple voltages on the second harmonic. As shown by research [18–21], overvoltages on the second harmonic can exist for a long time, so the decisive factor in determining the scattering energy is the time of the emergence of an abnormal regime with unloaded autotransformer.

The method described in the article solves the problem of putting the line under voltage, avoiding the danger of damage to electrical equipment by resonant overvoltages on the second harmonic. The use of pre-insertion resistors can reduce the amplitude and duration of this type of overvoltage. It is important to note that the decision to use pre-insertion resistors in each case must be supported by the results of mathematical analysis.

Thus, the use of pre-insertion resistances in SF6 circuit breakers has not been verified by influencing the characteristics of the aperiodic component.

The objective of the ASP is to reduce the electrostatic as well as the electromagnetic components of the feed current in order to ensure a successful SPAR [22–25].

Compared to air circuit breakers, SF6 circuit breakers have certain advantages, the main ones being performance and high switching capacity, as

well as the possibility of installing an additional controlled switching device. This device enables the switching of the gas switch at a predetermined moment in order to reduce the negative effects of transients. The switching moment of the air switch is random and it is not possible to open or close it at the right time. Such a fault during operation led to emergency situations, including the occurrence of resonant overvoltages in non-sinusoidal modes [15, 16, 18–21, 26, 27].

Initial transition conditions for each phase corresponding to the maximum and minimum of the sine wave voltage

$$\delta^A \in [0; 90; 180; 270; 360]; \delta^B \in [122; 212; 300]; \delta^C \in [60; 150; 240; 330]. \quad (5)$$

It should be noted that the paper considers the worst case when the voltage in the intact phases goes beyond zero and the case when the voltage reaches its maximum value. In the first case, such initial conditions of the electromagnetic switching transient cause the maximum initial value of the aperiodic component of the current. As it is shown by the damping the study of the aperiodic component of the current is determined by the ratio of the circuit's active resistance to the total inductance [1–3]. According to the data, the damping process for certain lines continues to 0.003–0.04 s. A controlled switching device for aperiodic suppression can be used in combination with the above.

As we can see from (1) $i_{ap}(t)$ depends on α – moment of commutation. So, we can say that controlling switch device can reduce these two components. All circuit breakers are equipped controlled switching device Switch Sync F236. The sinusoid with possible moments of commutation is depicted in Fig. 4. To assess the impact of the switching moment on the characteristics of the aperiodic component, a simulation model is developed and the description of which is given in the next section.




Fig. 4. Sine wave voltage phases A, B, C with designated switching points

When using controlled switching, the time constant will be equal to

$$\tau = \frac{AB(GR_M(R_{S1} + R_{S2})D(2F + 2G + I))}{DFR_E(AK + B(2L_M L_E + 2L_L L_E + L_M L_E)(L_{S1} + L_{S2}) + AB(GR_M(R_{S1} + R_{S2})D(2F + 2G + I))} \rightarrow \frac{AB(GR_M(R_{S1} + R_{S2})D(2F + 2G + I))}{+L_{S1}L_{S2}(2L_L(L_M + L_E) + L_M L_E)} \quad (6)$$

In case of switching-off the shunt reactor group, the decay time constant will be

$$\tau = \frac{AB(GR_M(R_{S1} + R_{S2})D(F + G + I))}{DFR_E(AK + B(L_M L_E + L_L L_E + L_M L_E)(L_{S1} + L_{S2}) + AB(GR_M(R_{S1} + R_{S2})D(F + G + I))} \rightarrow \frac{AB(GR_M(R_{S1} + R_{S2})D(F + G + I))}{+L_{S1}L_{S2}(L_L L_M + L_L L_E + L_M L_E)} \quad (7)$$

In case of application APS decay time constant will be

$$\tau = \frac{L_{S1}L_{S2}(R_{S1}R_{S2})}{R_{S1}R_{S2}(L_{S1} + L_{S2})} \quad (8)$$

To perform the time constant calculations, the following EHV power line data were adopted for the next lines: Khmelnytsky nuclear power plant (Ukraine) – Rzeszow (Poland), South-Ukrainian nuclear power plant (Ukraine) – Isaccea (Romania), Western Ukrainian (Ukraine) – Albertshire (Hungary). The resistance is $R_{pre-ins} = 400 \Omega$ for both cases shown in Fig. 3a, b. Parameters of equivalent systems and shunt reactors are shown in Tab. 1.

Table 1

Parameters of systems and shunt reactors

| Name of system | Impedance of system Z, Ω | Parameters of shunt reactor | | | |
|---|---------------------------------|---|--|--|--|
| | | Equal inductance of ground component shunt reactor L_M, H | Equal active resistance of ground component shunt reactor L_E, H | Equal resistance of ground component shunt reactor R_M, Ω | Equal inductance of ground component shunt reactor R_E, Ω |
| Khmelnytsky nuclear power plant (Ukraine) | 6.28 + 95.85i | 37.17 | 9.42 | 30 | 13.44 |
| Rzeszow (Poland) | 4.78 + 60.85i | | | | |
| South-Ukrainian nuclear power plant (Ukraine) | 6.88 + 77.65i | | | | |
| Isaccea (Romania) | 6.78 + 88.48i | | | | |
| Western Ukrainian (Ukraine) | 9.28 + 82.88i | | | | |
| Albertshire (Hungary) | 8.78 + 68.75i | | | | |

The calculations of the aperiodic time constant according to the expressions (3), (4), (6)–(8) are given in Tab. 2.

Table 2

Results of calculation of aperiodic time constant

| The name of case | Aperiodic time constant τ , s | | |
|-------------------------------------|--|---|---|
| | Khmelnytsky nuclear power plant (Ukraine) – Rzeszow (Poland) | South-Ukrainian nuclear power plant (Ukraine) – Isaccea (Romania) | Western Ukrainian (Ukraine) – Albertshire (Hungary) |
| Without measure | 0.097 | 0.098 | 0.1 |
| Pre-insertion resistors in series | 0.055 | 0.052 | 0.051 |
| Pre-insertion resistors in parallel | 0.093 | 0.095 | 0.098 |
| Automatic shunting of phase | 0.044 | 0.047 | 0.048 |
| Switching-off the SR group | 0.088 | 0.086 | 0.087 |
| Controlled switching device | 2.1 | 2.02 | 2.5 |

The task of using technical means is to reduce the duration and value of the aperiodic component. The duration of the aperiodic component is ensured by the highest value of the constant damping time. As it can be seen from the results in Tab. 2, the lowest constant time value is observed when using controlled switching. In the case of ASP, the lowest value will be observed, which will lead to the longest running of the aperiodic component.

For example, in [1–10] it is recommended to disable the shunt reactor group to reduce the characteristics of the aperiodic component. As you can see from the results, such an event reduces the time constant thereby increasing the duration of the transient. In fact, shutting down the bypass reactor group is ineffective. To test the efficiency, the results which are shown in Fig. 5 were evaluated.

As it can be seen from Fig. 5, the use of shutdown of the shunt reactor group does not lead to a significant change in the time constant, while further dragging on the value of the impedance resistance does not lead to the required increase in the time constant.

In order to verify the correctness of the equations and theoretical statements, a simulation model was developed for the analysis of electromagnetic transients in the TPAR cycle.




Fig. 5. Reducing the aperiodic time constant at different measures and means

Modelling of cycle three phase auto-reclose of extra high voltage transmission line

The model was developed to study the processes at single phase auto-reclose in the environment MatLab-Simulink which are illustrated on Fig. 6. Calculations were made to find the effective measure to prevent this kind of overvoltages. The three-phases power system is simulated by voltage sources with fixed voltage and inductance. The overhead line is simulated by two parts, which are given complex matrices with distributed elements or values on the forward and reverse sequence.




Fig. 6. Model of extra high voltage transmission line

Using the data of Tab. 1, we simulate EHV line modes using a specific measure and technique. Each case is illustrated in Fig. 7–10.




Fig. 7. Pre-insertion resistors connected in series




Fig. 8. Pre-insertion resistors connected in parallel




Fig. 9. Controlled switching device




Fig. 10. Automatic phase shunting

As it can be seen from Fig. 7–10, the simulation results confirm the theoretical assumptions about the duration of existence of the aperiodic component and the derived formulas (3), (4), (6)–(8). The shortest duration of the aperiodic component is observed when using controlled switching (Fig. 9). The highest duration is observed with the use of automatic phase shunting (Fig. 10). The use of pre-insertions with resistors also does not produce the required result (Fig. 7, 8).

CONCLUSION

1. When designing extra high voltage power lines, a careful analysis of the electromagnetic transients accompanying the switching during operation is necessary. Quick on-off cycles (symmetric or non-phase) should be avoided in case of TPAR. In particular, in such cases it is necessary to pay attention to the cycle of fast three-phases automatic reconnection, in which the switch may be damaged due to the aperiodic component of the current.

2. The results of the work confirm the theoretical principles, which consist in the inefficiency of using pre-insertion resistances and automatic phase shunting to reduce the characteristics of the aperiodic component of the current for the total transient process. This also applies to the disconnection of a group of shunt reactors as a measure. The derived formulas for the determination of the aperiodic time constant of the aperiodic component confirm the above

mentioned. Value resistance changing of the pre-insertion resistor when disconnecting the group of shunt reactors also confirmed the inefficiency of using the same means even when used together. This analysis without any significant assumptions was performed based on the mathematical models developed in MatLab which confirm the theoretical propositions.

Acknowledgments

This research is supported by the state youth grant “Development of measures and technical means of compensation of open phase modes of the bulk power electrical networks of the integrated electrical systems of Ukraine” – order of 09.01.2020 № 15 “On the results of the competition for grants of the NAS of Ukraine by research laboratories / groups of young scientists of the NAS of Ukraine for research in priority areas of science and technology in 2020”.

REFERENCES

1. Kuznetsov V. G., Tugai Yu. I., Shpolyansky O. G. (2017) Analysis of the Preconditions of SF6 Circuit Breakers Damage in 750 kV Electric Networks. *Praci Institutu Elektrodinamiki Natsional'noi Akademii Nauk Ukraini* [Proceedings of the Institute of Electrodynamics of the National Academy of Sciences of Ukraine], (47), 5–9. <https://doi.org/10.15407/publishing.2017.47.016> (in Ukrainian).
2. Naumkin I. E. (2012) Emergency Failures of SF6 Circuit Breakers when Switching Compensated 500–1150 kV Overhead Power Lines. *Elektrichestvo*, (10), 22–32 (in Russian).
3. Blumschein J., Yelgin Y., Ludwig A. (2017) Adaptive Autoreclosure to Increase System Stability and Reduce Stress to Circuit Breakers. *70th Annual Conference for Protective Relay Engineers (CPRE)*, 1–8. <https://doi.org/10.1109/cpre.2017.8090004>.
4. Silva F. F., Bak C. L., Gudmundsdottir U. S., Wiechowski W., Knardrupgard M. R. (2010) Methods to Minimize Zero-Missing Phenomenon. *IEEE Trans. on Power Del.*, 25 (4), 2923–2930. <https://doi.org/10.1109/tpwr.2010.2045010>.
5. Ji L., Booth C., Dyško A., Kawano F., Beaumont P. (2014) Improved Fault Location Through Analysis of System Parameters During Autoreclose Operations on Transmission Lines. *IEEE Transactions on Power Delivery*, 29 (6), 2430–2438. <https://doi.org/10.1109/TPWRD.2014.2307051>.
6. Li G., Yao S., Wang P., Yan D., Gao X., Yao Y. (2017) Discussion on the Problem About Capacitive Current Switching of EHV and UHV AC Circuit Breaker. *4th International Conference on Electric Power Equipment – Switching Technology (ICEPE-ST)*, Oct. 22–25, 2017. <https://doi.org/10.13296/j.1001-1609.hva.2018.03.034>.
7. Kachesov V. E., Kachesov D. V. (2011) Requirements for Switching Algorithms of EHV Shunt Compensated OHL by SF6 Circuit Breakers. *Proceedings of International Conference on Power Systems Transients (IPST 2011)*, June 14–17, 2011, Delft, 15–18.
8. Naumkin I., Balabin M., Lavrushenko N., Naumkin R. (2011) Simulation of the 500 kV SF6 Circuit Breaker Cutoff Process during the Unsuccessful Three-Phase Autoreclosing. *Proceedings of International Conference on Power Systems Transients (IPST 2011)*, June 14–17, 2011, Delft. Available at: https://www.ipstconf.org/papers/Proc_IPST2011/11IPST025.pdf.
9. Jian H., Xiaofeng J., Xiaoguang H. (2010) Automated Monitoring and Analysis for High Voltage Circuit Breaker. *5th IEEE Conference on Industrial Electronics and Applications*. Taichung, 560–564. <https://doi.org/10.1109/iciea.2010.5517076>.
10. Gong R., Wang S., Luo X. (2012) Analysis and Design in Extra High Voltage Circuit Breakers Employing Shunted Capacitors. *6th International Conference on Electromagnetic Field Problems and Applications*. Dalian, Liaoning, 1–4. <https://doi.org/10.1109/icef.2012.6310424>.
11. Lazimov T., Saafan E. A., Babayeva N. (2015) Transitional Processes at Switching-Off Capacitor Banks by Circuit-Breakers with Pre-Insertion Resistors. *Modern Electric Power Systems (MEPS)*. Wroclaw, 1–4. <https://doi.org/10.1109/meps.2015.7477204>.

12. Lazimov T., Imanov S., Saafan E. A. (2010) Transitional Recovery Voltages at Capacitive Currents Switching-Offs by Vacuum and SF₆ Circuit-Breakers. *Modern Electric Power Systems*. Wroclaw, 1–5. <https://doi.org/10.13140/RG.2.1.2156.9446>.
13. Kuchanskyi V. (2019) Application of Controlled Shunt Reactors for Suppression Abnormal Resonance Overvoltages in Assymetric Modes. *IEEE 6th International Conference on Energy Smart Systems (ESS)*. Kyiv, 122–125. <https://doi.org/10.1109/ess.2019.8764196>.
14. Kuchanskyi V. (2017) The Prevention Measure of Resonance Overvoltges in Extra High Voltage Transmission Lines. *IEEE First Ukraine Conference on Electrical and Computer Engineering (UKRCON)*. Kiev, 436–441. <https://doi.org/10.1109/ukrcon.2017.8100529>.
15. Tugay Y. (2009) The Resonance Overvoltages in EHV Network. *Proceedings of IEEE Sponsored Conference EPQU'09 – International Conference on Electrical Power Quality and Utilisation*. Sept. 15–17, 2009, Lodz, 14–18. <https://doi.org/10.1109/epqu.2009.5318812>.
16. Kuchanskyi V. (2017) The Application of Controlled Switching Device for Prevention Resonance Overvoltages in Nonsinusoidal Modes. *IEEE 37th International Conference on Electronics and Nanotechnology (ELNANO)*. Kiev, 394–399. <https://doi.org/10.1109/elnano.2017.7939785>.
17. *Live Tank Circuit Breakers. Buyer's Guide*. ABB AB. 2014. 152.
18. Chun-Lien Su, Po-Han Wang, Chi-Hsiang Liao, Min-Hung Chou (2016) Analysis of Harmonic Overvoltages During Transformer Energization for Mass Rapid Transit Systems. *10th International Conference on Compatibility, Power Electronics and Power Engineering (CPE-POWERENG)*. <https://doi.org/10.1109/CPE.2016.7544154>.
19. Abdulsalam S. G., Xu W. (2007) A Sequential Phase Energization Method for Transformer Inrush Current Reduction-Transient Performance and Practical Consideration. *IEEE Transactions on Power Delivery*, 22 (1), 208–216. <https://doi.org/10.1109/tpwr.2006.881450>.
20. Brunke J. H., Fröhlich K. J. (2001) Elimination of Transformer Inrush Currents by Controlled Switching. Part II: Application and Performance Considerations. *IEEE Transactions on Power Delivery*, 16 (2), 281–285. <https://doi.org/10.1109/61.915496>.
21. Cho C., Lee J., Min B. (2017) Application of Controlled Switching Device for High Voltage Circuit Breaker in KEPCO Real Power System. *4th International Conference on Electric Power Equipment – Switching Technology (ICEPE-ST)*. Xi'an, 492–495. <https://doi.org/10.1109/icepe-st.2017.8188892>.
22. Hasibar R. M., Legate A. C., Brunke J., Peterson W. G. (1981) The Application of Highspeed Grounding Circuit Breakers for Single-Pole Reclosing on 500 kV Power Systems. *IEEE Transactions on Power Apparatus and Systems*, PAS-100 (4), 1512–1515. <https://doi.org/10.1109/tpas.1981.316499>.
23. Baina H., Xin L., Jianyuan X. (2008) The Analysis of Secondary Arc Extinction Characteristics on UHV Transmission Lines. *International Conference on High Voltage Engineering and Application*. Chongqing, 516–519. <https://doi.org/10.1109/ichve.2008.4773986>.
24. Mizoguchi H., Hioki I., Yokota T., Yamagata Y., Tanaka K. (1998) Development of an Interrupting Chamber for 1000 kV Highspeed Grounding Circuit Breakers. *IEEE Transactions on Power Delivery*, 13 (2), 495–502. <https://doi.org/10.1109/61.660920>.
25. Chi T., Xin L., Jianyuan X., Zhen-xin G. (2008) Comparison and Analysis on Very Fast Transient Overvoltage Based on 550 kV GIS and 800 kV GIS. *International Conference on High Voltage Engineering and Application*. Chongqing, 288–291. <https://doi.org/10.1109/ichve.2008.4773930>.
26. Zhezhelenko I. V. (2018) The Main Directions of Improving the Efficiency of Production, Transmission and Distribution of Electrical Energy. *Energetika. Izvestiya Vysshikh Uchebnykh Zavedenii i Energeticheskikh Ob'edinenii SNG = Energetika. Proceedings of CIS Higher Education Institutions and Power Engineering Associations*, 61 (1), 28–35. <https://doi.org/10.21122/1029-7448-2018-61-1-28-35> (in Russian).
27. Lasy P. G., Meleshko I. N. (2019) Application of Polylogarithms to the Approximate Solution of the Inhomogeneous Telegraph Equation for the Distortionless Line. *Energetika. Izvestiya Vysshikh Uchebnykh Zavedenii i Energeticheskikh Ob'edinenii SNG = Energetika. Proceedings of CIS Higher Education Institutions and Power Engineering Associations*, 62 (5), 413–421. <https://doi.org/10.21122/1029-7448-2019-62-5-413-421> (in Russian).